

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CPR/183/07/05/26

Dated: 07/05/26

It is certified that an inspection team headed by ALOK KUMAR

(Name of Officers with designation) from LAB. ASSIST. (CHEMIST) PHED

inspected the SWAMI VIVEKANAND PUBLIC SCHOOL, PARSA, SARAN

(Name & Address of the school) on 07/05/26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. CPR/183 dated 07/05/26

of Dist. Water Testing (PHED Lab) certified that

the SWAMI VIVEKANAND PUBLIC SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 06/05/2027

Signature with Seal: Alok Kumar

Name

Designation

Name & Address of the Office / Department : PHED

To

PRINCIPAL

SWAMI VIVEKANAND PUBLIC SCHOOL,

(Name & Address of the Institution) PARSA, SARAN

(BIHAR), 841219

P.H. Division, Chapra

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTRICT LEVEL LABORATORY, CHAPRA (SARAN)

PUBLIC HEALTH DIVISION, CHAPRA

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES

SAMPLE COLLECTED ON 05-05-2026 BY CHANDAN KUMAR & RECEIVED IN THE LABORATORY ON 05-05-2026

PARTICULARS OF THE SAMPLE					PARAMETERS EXAMINED (VALUE IN MG/L except pH, Otherwise Mentioned)														
Sl. NO	Block	Gram Panchayat	Village/ Ward Number	Name of the Nearest person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkanity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Flouride	T.D.S	Arsenic	Bacteriological test
1	Parsa	Nagar Nigam	Sudami NIVEKA NAND Public School Harpur Parsa, Saran Bihar- pin- 841219 R.O water		0.9	7.2	233	98	102	10	06	12	10	0.1	0.0	0.2	152	0.0	NG
Min-Max Permissible Limit (IS:10500/2012)					1-5 NTU	6.5-8.5	-	200-600	200-600	75-200	30-100	250-1000	200-400	1.0-1.0 NR	45-45 NR	1-1.5	500-2000	0.01-0.01 NR	+VE -VE

Remarks- Analysed Sample of water within permissible limit. hence sample is suitable for drinking.

Memo No- CPH/183 / Chapra, Dated 07-05-2026

*BDL-Below detection limit.


 Signed **Chandan Kumar**
 DEPUTY
 P.H. Division, Chapra